



ADDENDUM TO SOLICITATION/OFFER AND
AWARD

1. ADDENDUM 2	2. EFFECTIVE DATE September 1, 2011	3. SOLICITATION NUMBER ITB 11-2	4. PROJECT NUMBER /PURCHASE ORDER N/A
----------------------	--	--	--

5. ISSUED BY DISTRICT BOARD OF TRUSTEES COLLEGE OF CENTRAL FLORIDA STEWART E. TRAUTMAN, JR. DIRECTOR OF PURCHASING 3001 SW COLLEGE ROAD OCALA FLORIDA 34478-1388	6. ADMINISTERED BY (if other than block #5)
--	---

7. AUTHORIZED REPRESENTATIVE NAME AND TELEPHONE NUMBER (SOLICITATOR) TO FILL IN ITEMS BELOW)

NAME: _____

TITLE: _____

TELEPHONE: _____ FAX: _____

EMAIL: _____

8. TYPE OF ACTION REQUESTED

Check one

- A. THE CHANGE ORDER IS ISSUED TO INCREASE/DEDREASE FUNDING AMOUNT AS SET FORTH IN ITEM 9 BELOW:
- B. THE ABOVE NUMBERED SOLICITATION IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES SET FORTH IN ITEM 9 BELOW:
- C. OTHER SET FORTH IN ITEM 9 BELOW

IMPORTANT: SOLICITATOR IS REQUIRED TO SIGN THIS DOCUMENT AND RETURN 1 ORIGINAL SIGNED COPY (IES) TO THE ISSUING OFFICE

(Authorized Representative or designee from block 8 above)

9. DESCRIPTION OF ADDENDUM:

- The date and time of the Bid Due Date is hereby changed from Tuesday September 6, 2011 at 2:00 PM (EST) to Tuesday September 13, 2011 at 2:00 PM (EST). The location for the bid submittals shall remain unchanged.
- The date and time of the Bid Opening is hereby changed from Tuesday September 6, 2011 at 2:01 PM (EST) to Tuesday September 13, 2011 at 2:01 PM (EST). The location of the bid opening shall remain unchanged.
- The verbiage for section 57, located on page 8 of the bid documents is hereby replaced to read: "**Liquidated Damages:** Time is of the essence in the Work provided for in these Construction Documents and there will be, on the part of the Owner, considerable monetary damage in the event the Work is not completed within the time fixed for the completion of the Contract, or within the time to which such completion may be extended by consent of the Owner. Inasmuch as the actual damages for such delay is impossible to exactly determine, the Bidder agrees that he/she and his/her surety shall be liable for and shall pay to the Owner the following liquidated damages:

For failure of the Contractor to be substantially completed with the Work within the time set forth in the Agreement Between Owner and Contractor; liquidated damages shall be in accordance with the following schedule:

CONTRACT AMOUNT	LIQUIDATED DAMAGES PER CALENDAR DAY
\$10,000 to \$100,000	\$100
\$100,000 to \$499,999	\$250 + 0.05% of contract amount exceeding \$100,000
\$500,000 to \$999,999	\$450 + 0.04% of contract amount exceeding \$500,000
\$1,000,000 to \$1,999,999	\$650 + 0.03% of contract amount exceeding \$1,000,000
\$2,000,000 to \$5,999,999	\$950 + 0.02% of contract amount exceeding \$2,000,000
\$6,000,000 and Greater	\$1,750 + 0.01% of contract amount exceeding \$6,000,000

For the purpose of computing liquidated damages only, no deduction shall be made from the contract amount for Owner Direct/Contractor Assisted Purchase of Project Related Material and Equipment of these Bidding Requirements. If the project has multiple phased substantial completion dates, liquidated damages for each phase shall be computed based on the contract amount allotted to each phase by the schedule of values."

- 4. The attached technical items 01-05, provided by Johnson, Smith Architects, PA. are hereby included as part of this addendum.

10. AUTHORIZED SIGNATURES

10A. NAME AND TITLE OF SIGNER (same as block #7 above)

10B. NAME AND TITLE OF CCF AUTHORIZED REPRESENTATIVE (or designee)

STEWART E. TRAUTMAN, JR. DIRECTOR OF PURCHASING
NAME (PRINT) TITLE

10C.

10D. DATE SIGNED


PRESIDENT OR DISTRICT BOARD OF TRUSTEES OF COLLEGE OF CENTRAL FLORIDA OR Authorized Designee
(Signature Required) 01-11

NAME (PRINT)

TITLE

CONTRACTOR REPRESENTATIVE

DATE SIGNED



Johnson, Smith Architects, P.A.
316 S.E. 8th Street, Ocala, Florida 34471
352 - 351 - 1963 352 - 351 - 0552 (fax)

**ADDENDUM NO. 2
01 SEPTEMBER 2011
BUILDING 15 STORAGE FACILITY
COLLEGE OF CENTRAL FLORIDA
OCALA, FLORIDA
BID # 11-2**

NOTICE TO BIDDERS

This Addendum shall be considered part of the Contract Documents for the above mentioned project as though it had been issued at the same time, and shall be incorporated integrally therewith.

Where provisions of the following supplementary data differ from those of the original Contract Documents, this Addendum shall govern and take precedence.

Bidders are hereby notified that they shall make any necessary adjustments in their estimates on account of this Addendum. It will be construed that each Bidder's Proposal is submitted with full knowledge of all modifications and supplemental data specified herein.

Item	Description	Reference
01	Drawing A200, Clarification: No patching or painting is required on the adjacent building. The owner will provide.	Drawings A200
02	Drawing A200, Clarification: Wall mounted propeller fans are identified on Sheet A200 and fan electrical requirements are shown on Sheet A300.	Drawings A200
03	Drawing A300, Clarification: Bidder to verify and include in the bid the necessary length of conduit and conductors to route from the new building electrical panel and the existing electrical transformer. Disregard notation of approximate length of this run. Contact the owner for access to the property and verify the distance.	Drawings A300
04	Drawing A300, Specification Section 164 Electrical Substitution Request: EMT (electrical metallic tubing) may be used in lieu of rigid steel conduit. EMT shall have compression fittings and not screw-type clamp fittings. No aluminum conduit is required for this project.	Drawings/Specs A300/164
05	Drawing A300, Specification Section 164 Electrical Substitution Request: Use of Schedule 40 PVC is not allowed. Schedule 80, as specified, is required.	Drawings/Specs A300/164

END OF ADDENDUM 2